



NOTES:

1. FINE HAIR BROOM FINISH ON ENTIRE WHEELCHAIR RAMP.
2. CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE APPLICABLE SECTIONS OF THE CURRENT CITY OF RIPON SPECIFICATIONS.
3. MATERIAL UNDER ENTIRE WHEELCHAIR RAMP SHALL BE COMPACTED TO 95% RELATIVE COMPACTION FOR A DEPTH OF 8".
4. RAMP SLOPE SHALL BE 1:12 MAXIMUM (8% MAX).
5. TRANSITION SLOPE (WINGS) SHALL BE 1:10 MAXIMUM (10% MAX).
6. PROVIDE TRUNCATED DOME PER ST-29.

NO.	REVISED	BY
△	11/10/04	MCP
DRAWN BY: KWZ		
CHECKED BY: MJM		
V:\25_City of Ripon Standards\Standard Specifications\Drawings\Streets\st-27.dwg		

**Typical Wheelchair Ramp
Detail for Commercial/
Industrial Applications**

CITY OF RIPON

APPROVED
<i>Matthew MacDade</i>
CITY ENGINEER RCE-58093
DATE: 12-4-2001
STANDARD NO. ST-27