



NOTES:

1. VALVE BOX SHALL BE CHRISTY NO. G12 TRAFFIC BOX OR EQUAL.
2. RISER PIPE TO BE ONE CONTINUOUS PIECE OF PVC PIPE (C900 CLASS 150 WATER PIPE). MINIMUM PIPE SIZE TO BE USED AS A RISER PIPE IS 12" DIAMETER. A CHRISTY G12 x P12 BOX EXTENSION OR AN APPROVED EQUAL MAY ALSO BE USED.
3. GROUT BETWEEN ENTIRE RISER PIPE AND VALVE BOX, GROUT SHALL BE A MINIMUM OF 1" THICK.
4. AC PATCH TO BE NO MORE THEN 1" IN DEPTH AND NO LESS THAN 1/2" IN DEPTH.
5. THE DIRT SHALL BE A MINIMUM OF 2" BELOW THE ANGLE VALVE.

NO.	REVISED	BY	Permanent and Temporary Blowoff Detail	APPROVED	 CITY ENGINEER RCE-28191
				DATE: 2-2-99	
				STANDARD NO. W-16	
DRAWN BY: MCP			CITY OF RIPON		
CHECKED BY: DJR					
<small>V:\25_City of Ripon Standards\Standard Specifications\Drawings\Water\W-16.dwg</small>					