


NOTES:

1. INSTALL A 12" AIR GAP MINIMUM BETWEEN FINISHED GRADE AND RP DEVICE.
2. ALL CONNECTIONS ON ASSEMBLY SHALL BE FLANGED FITTINGS.
3. REDUCED PRESSURE BACKFLOW PREVENTION DEVICE SHALL BE AN APPROVED BACKFLOW PREVENTION ASSEMBLY BY THE STATE OF CALIFORNIA DEPARTMENT OF HEALTH SERVICES. (SOME APPROVED EXAMPLES INCLUDE: AMES 4000SS OSY, WILKINS 375, WILKINS 975, ETC.)
4. ONCE INSTALLED AND FUNCTIONING THE GATE VALVES SHOULD BE CHAINED AND LOCKED OPEN.

NO.	REVISED	BY	<p>Reduced Pressure Principle Backflow Prevention Assembly for 3" and Larger</p>	APPROVED	 CITY ENGINEER RCE-28191
				DATE: 2-2-99	
DRAWN BY: MCP				<p>CITY OF RIPON</p>	<p>STANDARD NO. W-20</p>
CHECKED BY: DJR					
V:\25_City of Ripon Standards\Standard Specifications\Drawings\Water\W-20.dwg					