



NOTES:

1. BACKFILL SHALL BE A FRIABLE LOAM, TYP. OF CULTIVATED TOPSOILS LOCALLY, CONTAINING AT LEAST 2% HUMUS. IT SHALL BE REASONABLY FREE OF SUBSOIL, STONES, CLOUDS, STICKS OR OTHER OBJECTIONABLE EXTRANEIOUS MATTER OR DEBRIS. IT SHALL NOT CONTAIN TOXIC MATERIALS.
2. TREE SPECIES SHALL BE SELECTED OR APPROVED BY THE CITY.
3. CONTROL VALVE, BACKFLOW PREVENTION ASSEMBLY, AND CONTROLLER PER APPROVED ENGINEERED PLANS.
4. ROOT BARRIERS REQUIRED FOR ALL TREE PLANTING. TYPE AND DESIGN TO BE APPROVED BY THE CITY ENGINEER.

NO.	REVISED	BY	Typical Tree Well Detail	APPROVED
				<i>[Signature]</i> CITY ENGINEER RCE-28191
				DATE: 2-2-99
DRAWN BY: MCP			CITY OF RIPON	STANDARD NO. IRR-5
CHECKED BY: DJR				
SCALE: NONE				