



**NOTES:**

1. STABILIZED CONSTRUCTION SITE ACCESS SHALL BE CONSTRUCTED OF 3" MIN. CRUSHED ROCK, MATERIAL SHALL BE PLACED TO A MINIMUM THICKNESS OF 12 INCHES. THE ROCK ENTRANCE SHALL BE UNDERLINED WITH FILTER FABRIC, TO ELIMINATE ROCK BEING PUSHED INTO THE SOIL, AND THE SOIL PUMPING UP INTO THE ROCK BED.
2. LENGTH TO ENTRANCE SHALL BE A MINIMUM OF 50 FEET. WIDTH SHALL BE A MINIMUM OF 15 FT. OR GREATER IF NECESSARY TO COVER ALL VEHICULAR INGRESS AND EGRESS. PROVIDE AMPLE TURNING RADII.
3. THE ENTRANCE SHALL BE KEPT IN GOOD CONDITION BY OCCASIONAL TOP DRESSING WITH MATERIAL AS SPECIFIED IN NOTE 1.
4. ACCESSSES SHALL BE INSPECTED WEEKLY DURING PERIODS OF HEAVY USAGE, MONTHLY DURING NOMAL USAGE, AND AFTER EACH RAINFALL, WITH MAINTENANCE PROVIDED AS NECESSARY. PERIODIC TOP DRESSING SHALL BE DONE AS NEEDED.

NO.	REVISED	BY	<b>STABILIZED CONSTRUCTION ENTRANCE</b>	APPROVED
				 CITY ENGINEER 58093
DRAWN BY: AJM				DATE: 12-12-06
CHECKED BY: CPB				<b>CITY OF RIPON</b>
SCALE: NONE			STANDARD NO. <b>SWPP-5</b>	