



**NOTES:**

1. AN OUTSIDE DROP TYPE MANHOLE SHALL BE USED WHERE THE DIFFERENCE IN ELEVATION BETWEEN THE TOP OF THE MAIN LINE AND THE FLOWLINE OF THE FEEDER PIPE EXCEEDS 24" (2'-0").
2. DROP PIPE TO BE ONE PIPE SIZE LARGER THAN THE INCOMING PIPE.
3. BOTTOM MANHOLE SECTION SHALL BE WET-SET OR SET IN FORMED GROOVE WITH RAMSNECK.

NO.	REVISED	BY	<p><b>Sanitary Sewer Drop Manhole (Exterior Piping)</b></p>	APPROVED	 CITY ENGINEER RCE-28191
				DATE: 2-2-99	
DRAWN BY: MATT				STANDARD NO. <b>S-7</b>	
CHECKED BY: DJR			<b>CITY OF RIPON</b>		
<small>V:\125_City of Ripon Standards\Standard Specifications\Drawings\Sewer\S-7.dwg</small>					