

Concrete Curb, Gutter and Sidewalk Construction Notes

1. Curb and gutter construction shall conform to Section 73, California Department of Transportation Standard Specifications, except as modified herein.
2. Reference is made to Section 13 of the City of Ripon Standard Specifications for requirements relating to the construction of concrete curb, gutter, and sidewalk.
3. Subgrade for curb, gutter and sidewalk shall be compacted to a minimum relative compaction of 95% to a depth of 8" (inches). Where the subgrade "R" value is less than 50, place 4" (inches) of aggregate sub-base under the concrete sections and compact to a minimum of 95%.
4. All concrete radii are 3/4" unless noted.
5. Concrete shall be Class B, per CALTRANS Section 90. One pound of lampblack shall be added per cubic yard of concrete.
6. Expansion joints and weakened plane joints shall be installed as indicated on the plans or standard details.
7. Curb, gutter and sidewalk shall have a light broom finish.
8. Depress a 2" high letter "W", "NP" or "S" 1/4" deep into the face of the curb to identify service locations. Letters to be placed as read from the street.
9. During construction of gutters, water test the flow to insure proper drainage.

NO.	REVISED	BY	Concrete Curb, Gutter and Sidewalk Standards	APPROVED	 CITY ENGINEER RCE-28191
				DATE: 2-2-99	
DRAWN BY: Matt				STANDARD NO. ST-20	
CHECKED BY: DJR			CITY OF RIPON		
V:\25_City of Ripon Standards\Standard Specifications\Drawings\Streets\st-20.dwg					