

ALL FIRE LANES REQUIRED BY THE RIPON CONSOLIDATED FIRE DISTRICT ARE REQUIRED TO MEET THE REQUIREMENTS OF CITY OF RIPON STANDARD W-10.


WIDTH: FIRE LANES ARE REQUIRED TO BE A MINIMUM OF TWENTY (20) FEET IN WIDTH, ALONG THE FULL LENGTH OF REQUIRED LANE.

SURFACE: FIRE LANES ARE TO BE CONSTRUCTED OF ASPHALT OR CONCRETE, UNLESS APPROVED OTHERWISE BY THE CITY ENGINEER AND THE FIRE MARSHALL.

MARKING:

1. CURBS ON EITHER SIDE OF LANE SHALL BE PAINTED RED AND THE WORDS "NO STOPPING - FIRE LANE" ARE TO BE PAINTED ON THE FACE OF CURB. THESE LETTERS ARE TO BE A MINIMUM OF 4 INCHES IN HEIGHT AND ARE TO BE WHITE IN COLOR, AND SPACED AT INTERVALS OF NOT MORE THAN 25 FEET APART.
2. IF NO CURBS ARE PRESENT TO DELINEATE THE WIDTH OF THE LANE, THE OUTER BOUNDARIES OF THE LANE WILL BE MARKED WITH A RED LINE THAT IS A MINIMUM OF 4 INCHES IN WIDTH. THE LINE SHALL RUN THE FULL LENGTH OF REQUIRED LANE, AND PLACED ON ANY SIDE THAT IS NOT BORDERED BY A CURB.
3. THE ENTIRE FIRE LANE SHALL BE MARKED WITH DIAGONAL PAINTED WHITE LINES, RUNNING ACROSS THE FULL WIDTH OF THE LANE. THESE LINES ARE TO BE SPACED NO MORE THAN TEN (10) FEET APART AND ARE TO BE NO LESS THAN 2.5 INCHES IN WIDTH.
4. THE WORDS "FIRE LANE - NO STOPPING" ARE TO BE PAINTED ON THE DRIVING SURFACE AT A SPACING NOT TO EXCEED EVERY FIFTY (50) FEET, UNLESS OTHERWISE SPECIFIED. THE LETTERS ARE TO BE NO LESS THAN 8 INCHES TALL UNLESS APPROVED BY THE CITY ENGINEER AND FIRE MARSHALL.

SIGNAGE: SIGNS SHALL BE POSTED AT EACH ENTRANCE AND EVERY 75 FEET IN BETWEEN, STATING "NO STOPPING - FIRE LAND". THE SIGN SHALL MEET THE REQUIRMENTS OF THE CALIFORNIA DEPARTMENT OF TRANSPORTATION, SIGN NUMBER R26F. THE SIGN IS ALSO TO STATE "CVC 22500.1".

NO.	REVISED	BY	Fire Lane Notes	APPROVED	
				CITY ENGINEER	58093
DRAWN BY: MCP				DATE:	11-07-00
CHECKED BY: DJR				CITY OF RIPON	
V: 125 City of Ripon Standards Standard Specifications Drawings Water w-10a.dwg					