



NOTES:

1. SAMPLING STATION BOX / METER BOX TO BE INSTALLED PER CITY OF RIPON STANDARD W-14.
2. METER BOX SHALL BE CHRISTY NO. B-24 OR APPROVED EQUAL. BOXES IN TRAFFIC AREAS SHALL HAVE TRAFFIC RATED COVERS. ALL COVERS SHALL HAVE A METER READING LID, A CHRISTY B24g IN NON-TRAFFIC AREAS AND A CHRISTY B24-61g IN TRAFFIC AREAS.
3. WATER SAMPLING STATION SHALL BE SET USING A FORD 70-80 SERIES COPPERSETTER (PART NO. VBH-74-84-11-44 WITH C86-44 ADAPTER).
4. WATER METER SHALL BE A BADGER RECORDALL 1" DISK METER, PART NO. RCDL 70.
5. ALL SAMPLING STATIONS SHALL BE PROVIDED AND INSTALLED BY THE DEVELOPER AND/OR CONTRACTOR. A WATER PLUS PROBE ROD (PART NO. 150G) SHALL BE PROVIDED TO THE CITY OF RIPON FOR EVERY SAMPLING STATION REQUIRED.
6. WATER SAMPLING STATION SHALL BE A WATER PLUS ALL-IN-ONE SAMPLE STATION (MODEL #15001034).
7. SAMPLING STATIONS SHALL BE PLACED WITHIN SUBDIVISIONS AS DETERMINED BY THE CITY OF RIPON.

NO.	REVISED	BY	<h2 style="margin: 0;">Water Sampling Station Detail</h2>	APPROVED	 CITY ENGINEER RCE-28191	
				DATE: 2-2-99		
DRAWN BY: MCP				<h1 style="margin: 0;">CITY OF RIPON</h1>		STANDARD NO. W-26
CHECKED BY: DJR						
<small>V: 125_City of Ripon Standards Standard Specifications Drawings Water W-26.dwg</small>						